

102 年 10 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
10/01	24.8	6.9	6.3	23.2	5.7
10/02	24.8	6.9	5.6	26.0	6.6
10/03	27.3	6.8	7.1	22.4	7.0
10/04	25.5	6.9	6.7	23.9	7.2
10/05	26.8	6.9	5.2	22.6	--
10/06	26.2	7.0	7.9	25.8	--
10/07	27.4	6.8	6.2	24.6	8.7
10/08	27.1	6.9	5.7	23.4	5.8
10/09	27.4	7.0	6.7	25.9	7.0
10/10	27.9	6.9	7.7	23.1	--
10/11	27.8	6.9	5.3	25.5	6.7
10/12	26.9	7.0	8.0	23.0	--
10/13	27.1	7.0	6.6	21.4	--
10/14	28.2	6.8	6.5	23.4	6.9
10/15	28.1	6.9	7.7	26.2	6.5
10/16	26.9	6.9	6.7	25.8	7.4
10/17	25.9	6.7	6.4	24.9	7.7
10/18	26.0	6.9	5.3	22.9	6.0
10/19	27.4	7.0	5.9	26.2	--
10/20	27.2	6.9	6.3	27.4	--
10/21	26.6	6.7	5.0	22.0	7.0
10/22	26.2	6.8	5.2	24.1	8.4
10/23	26.0	8.9	6.2	29.9	7.6
10/24	26.6	6.9	6.3	23.3	6.8
10/25	26.3	6.9	6.4	23.6	7.0
10/26	26.5	6.9	8.0	27.7	--
10/27	26.3	6.9	6.5	28.5	--
10/28	26.1	6.6	6.6	26.1	7.1
10/29	26.0	6.9	6.2	23.5	6.6
10/30	26.0	6.7	6.1	25.9	6.1
10/31	27.3	6.8	7.1	27.5	7.2
平均值	26.7	6.9	6.4	24.8	7.0