

103 年 04 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
04/01	25.8	6.8	7.1	25.9	7.1
04/02	25.4	6.9	6.5	27.5	6.9
04/03	25.6	6.9	10.6	27.6	7.1
04/04	25.4	6.9	7.6	25.6	--
04/05	25.8	6.8	10.4	25.6	--
04/06	25.5	6.9	10.0	29.6	--
04/07	25.9	6.8	6.8	28.0	7.6
04/08	26.6	6.9	7.6	28.8	6.9
04/09	26.2	6.8	6.3	27.1	7.3
04/10	26.5	6.9	7.6	28.7	7.1
04/11	25.5	6.9	8.6	29.4	7.8
04/12	25.5	6.8	6.8	29.0	--
04/13	25.7	6.9	11.8	29.0	--
04/14	27.0	6.9	10.2	29.8	--
04/15	26.1	6.9	6.9	30.5	7.0
04/16	20.8	7.0	5.8	28.9	7.1
04/17	26.2	7.0	7.7	29.7	7.4
04/18	27.3	7.0	6.2	29.2	7.5
04/19	25.9	6.9	6.6	30.4	--
04/20	25.8	6.9	7.2	29.6	--
04/21	26.3	7.0	6.8	27.2	--
04/22	27.4	7.0	7.2	28.7	7.4
04/23	27.5	6.8	7.6	26.7	7.0
04/24	27.2	6.8	6.6	30.9	8.2
04/25	27.0	7.0	6.2	28.8	7.2
04/26	26.0	6.8	7.4	28.4	--
04/27	25.6	6.9	7.2	30.8	--
04/28	27.3	7.1	7.1	30.0	--
04/29	27.2	6.9	6.2	30.0	7.6
04/30	27.5	6.8	7.3	29.1	7.2
平均值	26.3	6.9	7.6	28.7	7.3