

103 年 05 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
05/01	26.9	6.9	7.3	28.7	8.0
05/02	27.0	6.8	7.6	25.7	8.1
05/03	24.1	6.9	6.8	30.1	--
05/04	25.1	6.9	10.0	26.2	--
05/05	27.1	6.8	7.0	26.2	--
05/06	26.5	7.0	8.6	27.5	6.0
05/07	27.0	7.1	7.0	25.1	9.9
0508	26.8	7.0	7.3	31.1	7.9
04509	27.0	7.1	8.5	29.2	7.4
05/10	25.2	6.9	6.1	30.8	--
05/11	24.8	6.9	6.9	26.8	--
05/12	27.7	7.0	7.8	27.6	--
05/13	28.1	7.0	11.5	31.9	7.4
05/14	26.9	7.0	7.8	29.0	7.2
05/15	27.2	6.9	7.6	28.6	6.4
05/16	28.0	6.9	7.4	30.0	7.1
05/17	27.9	6.9	6.6	23.7	--
05/18	25.6	6.9	7.5	22.9	--
05/19	28.9	6.9	6.9	27.3	--
05/20	28.1	6.9	6.9	26.0	7.8
05/21	28.1	7.0	7.4	29.7	7.2
05/22	27.9	6.7	9.0	30.7	6.5
05/23	28.1	6.8	10.5	22.9	8.6
05/24	25.5	6.9	7.9	28.2	--
05/25	26.1	6.9	7.4	26.6	--
05/26	28.7	6.8	6.6	27.4	--
05/27	28.1	6.7	6.3	31.2	7.2
05/28	28.3	7.0	6.2	29.6	6.9
05/29	28.7	6.8	8.0	26.9	7.5
05/30	28.5	7.1	9.4	31.2	8.1
05/31	28.1	7.0	6.0	24.1	--
平均值	27.2	6.9	7.7	27.8	7.5