

## 103 年 06 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
06/01	26.7	7.0	9.9	23.7	--
06/02	27.8	7.0	7.9	27.7	--
06/03	28.0	6.9	5.8	30.0	7.8
06/04	27.3	6.9	6.8	31.6	7.3
06/05	28.2	7.0	7.6	28.3	6.6
06/06	27.7	7.0	7.3	31.2	7.1
06/07	27.0	6.8	5.3	25.5	--
06/08	27.3	7.0	6.4	29.1	--
06/09	28.8	7.1	7.1	31.5	--
06/10	28.4	7.2	7.9	29.7	7.5
06/11	28.6	7.0	7.0	25.5	7.1
06/12	28.6	7.0	7.2	28.2	7.7
06/13	28.4	7.0	5.6	31.7	8.4
06/14	28.1	7.0	6.7	27.9	--
06/15	27.8	6.9	6.3	27.1	--
06/16	28.5	6.9	6.7	33.1	--
06/17	28.4	6.8	8.9	29.2	7.9
06/18	28.6	6.8	5.6	32.5	7.1
06/19	28.9	6.9	8.4	31.2	7.6
06/20	28.5	7.0	7.0	30.7	8.1
06/21	28.8	6.8	10.5	30.2	--
06/22	28.2	6.8	7.9	31.7	--
06/23	28.3	6.8	6.6	29.0	--
06/24	29.0	7.1	7.2	28.2	6.7
06/25	29.0	7.1	9.8	28.7	7.0
06/26	28.4	7.1	6.6	31.7	7.6
06/27	26.9	7.0	10.5	26.8	6.9
06/28	29.1	7.1	5.9	28.7	--
06/29	28.6	7.2	7.1	27.1	--
06/30	29.2	6.9	7.7	25.5	--
平均值	28.2	7.0	7.4	29.1	7.4