

## 103 年 07 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
07/01	29.4	6.9	8.0	26.3	7.8
07/02	29.4	6.8	5.9	29.6	7.0
07/03	29.5	6.8	9.4	29.5	6.8
07/04	29.1	7.0	11.6	26.4	7.3
07/05	28.8	7.0	6.8	33.5	--
07/06	29.2	7.0	6.6	33.5	--
07/07	29.1	6.9	6.9	29.5	--
07/08	29.0	7.2	6.2	25.5	8.1
07/09	29.0	6.9	8.7	32.3	6.7
07/10	29.0	6.9	5.2	28.7	8.1
07/11	29.8	7.0	8.8	32.5	7.2
07/12	28.9	7.0	6.6	29.1	--
07/13	28.7	7.0	4.6	29.1	--
07/14	28.7	7.0	8.3	30.7	--
07/15	29.1	6.9	6.0	31.7	7.7
07/16	29.3	6.9	10.2	27.8	6.8
07/17	29.2	7.0	5.3	27.2	9.0
07/18	29.1	6.9	8.3	31.2	8.6
07/19	28.5	7.0	7.0	32.1	--
07/20	28.6	7.0	6.2	29.7	--
07/21	29.0	6.9	5.4	30.5	--
07/22	28.6	6.9	8.8	29.7	6.7
07/23	28.3	6.9	7.5	30.2	7.4
07/24	28.8	6.8	7.1	30.7	6.6
07/25	28.4	6.9	8.0	26.7	7.0
07/26	28.6	6.9	11.8	29.4	--
07/27	28.9	6.9	5.5	24.6	--
07/28	29.0	6.9	7.1	30.2	--
07/29	29.1	6.8	8.0	29.8	7.0
07/30	29.1	6.8	7.2	30.9	6.8
07/31	29.0	6.8	9.4	27.2	7.1
平均值	29.0	6.9	7.5	29.5	7.4