

## 103 年 08 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
08/01	29.0	6.9	8.4	27.6	7.0
08/02	29.0	6.9	7.8	28.7	--
08/03	29.4	6.9	9.0	31.1	--
08/04	29.0	7.0	7.9	29.9	--
08/05	29.2	6.8	7.0	32.3	6.8
08/06	28.8	6.9	6.5	29.1	7.7
08/07	29.0	6.9	6.8	26.3	8.1
08/08	29.0	6.9	9.5	31.2	7.4
08/09	28.7	6.9	9.8	26.6	--
08/10	27.5	6.9	9.6	25.8	--
08/11	28.0	6.9	8.2	28.2	--
08/12	27.8	7.0	7.4	29.7	7.1
08/13	28.7	6.9	6.5	27.3	7.7
08/14	28.0	6.8	5.6	26.0	6.3
08/15	28.7	7.0	6.9	30.7	7.3
08/16	28.5	6.9	8.1	32.7	--
08/17	27.6	6.9	6.6	27.1	--
08/18	29.0	6.8	8.4	25.1	--
08/19	27.6	6.8	6.8	30.7	7.0
08/20	28.6	6.9	8.0	25.1	7.5
08/21	28.6	7.0	8.5	24.1	6.8
08/22	28.9	6.9	8.7	26.9	7.2
08/23	27.5	6.9	6.9	31.6	--
08/24	28.2	6.9	9.2	30.0	--
08/25	28.6	6.9	5.1	27.6	--
08/26	28.9	6.8	8.8	25.5	7.4
08/27	28.9	7.1	8.2	30.3	7.0
08/28	28.5	6.9	9.5	29.5	6.8
08/29	29.1	6.9	9.4	28.4	7.2
08/30	27.3	6.8	9.4	26.0	--
08/31	27.5	6.9	8.9	26.8	--
平均值	28.5	6.9	8.0	28.3	7.2