

## 103 年 09 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
09/01	28.6	7.0	9.0	29.2	
09/02	28.7	7.0	6.4	29.2	7.4
09/03	28.8	6.8	7.3	28.8	7.2
09/04	29.1	6.9	7.0	31.6	6.8
09/05	27.0	7.0	5.8	30.3	7.6
09/06	28.0	6.9	7.1	29.9	--
09/07	28.6	6.7	8.3	29.1	--
09/08	27.8	7.0	7.1	28.3	--
09/09	28.8	6.8	6.6	27.1	7.0
09/10	29.5	6.8	7.0	30.3	7.8
09/11	28.6	7.0	7.6	30.3	7.6
09/12	28.9	6.9	8.3	27.8	8.1
09/13	28.9	6.9	9.0	30.7	--
09/14	28.7	6.9	7.8	29.9	--
09/15	29.0	6.8	7.8	34.3	--
09/16	29.0	6.9	11.4	30.6	7.1
09/17	29.0	6.8	11.6	30.6	6.8
09/18	29.3	6.9	7.8	31.7	6.4
09/19	29.2	6.8	9.3	30.5	7.0
09/20	28.5	6.9	7.4	31.3	--
09/21	28.2	6.9	7.9	29.7	--
09/22	28.3	6.9	7.0	34.5	--
09/23	28.4	6.9	6.2	29.5	6.4
09/24	28.6	6.9	9.1	27.2	6.6
09/25	28.0	6.8	6.6	28.7	6.1
09/26	28.6	6.8	10.5	31.1	7.7
09/27	28.5	6.9	7.0	29.5	--
09/28	28.5	6.9	6.9	30.3	--
09/29	28.3	6.8	6.2	26.3	--
09/30	28.7	6.8	6.0	26.4	7.0
平均值	28.6	6.9	7.8	29.8	7.1