

102 年 12 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
12/01	24.9	6.7	4.1	20.6	--
12/02	24.4	6.7	4.3	20.6	--
12/03	24.5	6.8	5.8	21.8	5.4
12/04	24.4	6.8	6.5	27.5	6.3
12/05	24.1	7.0	8.8	27.6	7.1
12/06	24.4	6.9	6.6	23.5	5.1
12/07	25.1	6.9	2.9	25.2	--
12/08	25.1	6.8	7.6	25.2	--
12/09	24.4	6.8	5.6	25.2	--
12/10	25.3	6.6	6.4	23.0	6.2
12/11	24.1	6.8	3.5	22.2	5.7
12/12	24.3	6.9	6.8	26.6	7.3
12/13	24.9	6.9	5.5	23.6	6.0
12/14	24.4	6.9	6.0	24.9	--
12/15	24.4	6.9	7.5	23.5	--
12/16	25.4	6.6	9.6	26.7	--
12/17	24.1	6.7	9.1	20.7	5.5
12/18	24.5	6.8	2.8	23.2	6.4
12/19	22.7	6.9	9.6	22.2	5.9
12/20	24.1	6.7	7.1	23.0	6.3
12/21	23.5	7.0	5.8	29.6	--
12/22	23.8	6.9	9.2	20.8	--
12/23	23.9	6.7	6.6	24.0	--
12/24	23.5	6.8	7.5	26.0	6.6
12/25	24.5	6.4	8.8	25.7	6.8
12/26	24.0	6.8	8.4	29.5	5.7
12/27	23.3	6.7	6.1	30.3	6.2
12/28	23.3	6.7	6.8	31.0	--
12/29	23.2	6.7	8.8	29.8	--
12/30	23.2	6.7	4.6	27.4	--
12/31	23.6	6.5	7.9	24.8	6.8
平均值	24.2	6.8	6.7	25.0	6.2