

104 年 1 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
01/01	23.1	7.0	11.5	29.9	
01/02	22.9	7.0	12.3	31.5	
01/03	23.6	7.0	8.0	32.3	
01/04	25.0	6.9	9.0	30.7	
01/05	25.4	7.1	9.3	33.5	
01/06	25.7	6.9	7.0	36.7	8.2
01/07	25.9	6.7	9.3	30.3	6.5
01/08	25.4	6.9	9.1	25.6	7.8
01/09	24.7	6.8	10.2	23.2	7.0
01/10	24.9	6.9	3.7	18.0	
01/11	24.7	6.9	6.2	26.0	
01/12	25.4	6.8	7.0	20.4	
01/13	25.7	7.0	6.0	22.1	6.9
01/14	25.4	6.7	6.6	26.8	7.8
01/15	25.1	6.6	6.3	24.1	7.3
01/16	25.0	6.7	6.9	24.9	8.0
01/17	22.1	7.1	10.4	29.3	
01/18	22.7	7.0	9.0	24.5	
01/19	25.3	6.8	11.4	22.9	
01/20	25.3	6.8	6.0	18.9	7.0
01/21	25.4	6.8	9.6	26.5	7.9
01/22	25.0	6.7	8.0	31.4	8.2
01/23	25.3	6.7	9.0	24.9	7.5
01/24	24.8	7.0	6.5	32.4	
01/25	24.2	6.8	6.0	29.6	
01/26	25.9	6.8	6.3	30.4	
01/27	25.5	6.6	6.9	32.4	7.0
01/28	25.7	6.7	6.5	30.5	6.6
01/29	25.8	6.6	5.8	19.6	6.8
01/30	25.3	6.5	6.2	20.2	7.5
01/31	24.2	7.0	5.9	24.8	
平均值	24.9	6.8	7.8	26.9	7.4