

104 年 3 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
03/01	23.1	6.8	8.0	26.0	
03/02	25.8	6.7	8.0	27.2	
03/03	26.1	6.9	8.6	30.8	6.0
03/04	25.5	6.7	11.8	28.8	8.2
03/05	26.2	6.9	11.4	29.1	7.6
03/06	26.3	6.9	10.6	32.1	8.0
03/07	26.0	6.8	10.6	32.4	
03/08	26.2	6.9	8.4	28.4	
03/09	26.5	6.7	9.5	26.0	
03/10	25.6	6.7	12.0	27.5	7.3
03/11	25.5	6.6	9.5	24.8	7.5
03/12	25.4	6.7	8.1	28.0	8.2
03/13	25.5	6.4	9.4	28.1	7.6
03/14	25.2	6.9	6.5	24.2	
03/15	25.0	6.9	9.1	24.2	
03/16	26.7	6.8	5.5	29.0	
03/17	27.0	6.8	8.1	30.3	7.0
03/18	27.1	6.7	10.5	28.6	7.4
03/19	27.1	6.8	11.8	29.6	7.6
03/20	27.4	6.9	9.1	26.0	6.5
03/21	25.3	6.9	10.0	42.0	
03/22	24.5	7.2	9.3	28.8	
03/23	26.8	6.8	5.0	26.4	
03/24	26.4	6.9	8.1	21.3	6.9
03/25	26.6	6.8	10.3	29.3	7.5
03/26	26.1	6.6	7.3	31.2	8.2
03/27	26.3	6.6	5.7	27.2	7.0
03/28	26.4	6.8	8.2	26.8	
03/29	26.5	6.9	7.4	22.8	
03/30	27.4	6.8	7.0	26.0	
03/31	27.6	6.8	6.5	32.0	7.6
平均值	26.1	6.8	8.8	28.2	7.4