

104 年 4 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
04/01	27.6	6.8	10.4	25.9	8.0
04/02	27.9	6.8	4.4	26.7	6.6
04/03	26.1	6.9	8.8	30.3	
04/04	26.9	6.9	9.7	23.9	
04/05	27.2	6.8	10.6	23.1	
04/06	26.3	6.8	9.3	31.1	
04/07	28.0	6.7	6.4	33.5	7.4
04/08	27.0	6.6	8.9	25.0	6.5
04/09	27.0	6.7	5.8	22.2	8.6
04/10	27.2	6.7	8.9	25.2	8.0
04/11	27.2	6.7	7.4	27.5	
04/12	27.2	6.8	5.6	21.1	
04/13	26.5	6.5	11.3	25.1	
04/14	26.0	6.9	6.6	27.6	6.6
04/15	26.3	6.8	9.4	29.3	7.0
04/16	27.0	6.6	5.9	30.3	7.5
04/17	27.3	6.7	5.8	21.0	6.3
04/18	25.7	6.9	6.3	35.7	
04/19	27.3	6.9	5.5	27.7	
04/20	27.9	6.7	3.5	28.5	
04/21	27.5	6.9	8.0	24.1	7.0
04/22	27.8	6.8	8.4	28.4	7.9
04/23	27.4	6.8	6.4	28.9	8.9
04/24	27.7	6.8	5.3	24.8	8.0
04/25	27.8	6.9	5.7	29.2	
04/26	26.9	7.0	5.3	22.4	
04/27	28.1	6.8	8.1	27.2	
04/28	28.4	6.8	5.9	28.0	7.0
04/29	28.4	6.8	6.3	25.2	6.2
04/30	28.4	6.8	5.3	22.1	
平均值	27.3	6.8	7.2	26.7	7.3