

104 年 7 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
07/01	29.5	7.0	10.4	25.2	3.2
07/02	29.3	6.8	6.2	29.1	3.4
07/03	29.4	6.9	4.0	28.3	2.2
07/04	28.5	7.1	3.6	31.6	
07/05	28.3	7.0	5.1	31.2	
07/06	29.7	6.7	7.2	24.8	
07/07	29.2	7.0	3.8	28.7	4.2
07/08	28.5	6.9	6.8	30.3	<2.0
07/09	28.9	6.8	6.4	21.3	2.8
07/10	28.7	6.9	11.5	25.9	<2.0
07/11	28.8	7.0	4.2	29.6	
07/12	28.9	7.0	6.2	34.4	
07/13	29.1	6.8	6.7	37.2	
07/14	29.2	6.9	5.6	32.0	2.9
07/15	29.2	6.9	11.3	31.3	4.0
07/16	29.0	6.8	5.1	34.8	3.2
07/17	29.1	6.9	5.1	24.9	<2.0
07/18	29.0	7.1	5.7	31.2	
07/19	27.3	7.0	5.2	25.6	
07/20	28.6	6.7	6.9	26.4	
07/21	28.5	6.9	3.0	22.2	2.4
07/22	29.2	6.9	10.2	30.3	<2.0
07/23	28.7	6.8	6.4	27.1	<2.0
07/24	28.9	6.8	2.7	25.3	4.5
07/25	28.4	6.7	5.3	26.3	
07/26	29.7	6.9	4.0	27.1	
07/27	29.1	6.8	5.0	31.1	
07/28	29.1	6.9	4.4	29.5	2.0
07/29	28.9	6.8	3.8	32.7	<2.0
07/30	29.0	6.9	4.5	26.7	8.0
07/31	28.9	7.0	3.1	27.1	3.7
平均值	28.9	6.9	5.8	28.7	3.1