

104 年 8 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/01	29.2	7.0	3.6	35.9	
08/02	28.7	6.9	3.0	31.9	
08/03	29.1	6.7	6.6	25.1	
08/04	28.8	6.7	4.0	27.4	5.5
08/05	28.9	6.8	3.7	34.8	4.4
08/06	29.3	7.0	8.1	32.5	3.0
08/07	28.9	6.8	3.3	29.7	2.0
08/08	27.0	7.0	15.8	20.3	
08/09	27.2	7.1	4.0	24.3	
08/10	28.7	7.0	5.0	26.7	
08/11	28.9	7.0	4.1	26.7	<2.0
08/12	29.2	7.1	4.1	28.8	<2.0
08/13	28.3	6.9	6.1	28.1	5.2
08/14	29.2	6.8	5.5	24.4	<2.0
08/15	28.3	6.9	6.7	23.9	
08/16	28.9	6.8	5.8	21.5	
08/17	28.8	6.9	5.7	32.7	
08/18	28.6	6.9	8.1	36.3	2.3
08/19	28.7	6.9	13.1	27.6	<2.0
08/20	28.9	6.9	9.8	22.3	<2.0
08/21	28.7	7.0	11.9	26.2	<2.0
08/22	29.1	7.0	6.9	23.1	
08/23	28.1	7.1	13.7	24.7	
08/24	28.8	7.1	3.6	28.3	
08/25	28.4	7.0	8.2	33.3	<2.0
08/26	28.1	6.9	9.1	34.8	4.0
08/27	28.2	7.0	6.7	30.8	<2.0
08/28	28.2	7.0	3.8	28.0	2.5
08/29	28.9	7.1	9.3	32.4	
08/30	27.7	7.2	5.3	34.8	
08/31	27.7	7.1	7.0	25.2	
平均值	28.6	7.0	6.8	28.5	2.8