

104 年 9 月科技部南部科學工業園區台南園區污水處理廠放流水質

| 日期 | Temp (°C) | pH | SS (mg/L) | COD (mg/L) | BOD ₅ (mg/L) |
|-------|-----------|-----|-----------|------------|-------------------------|
| 09/01 | 27.9 | 7.1 | 7.9 | 25.4 | <2.0 |
| 09/02 | 28.1 | 7.1 | 9.6 | 25.8 | 4.9 |
| 09/03 | 28.5 | 7.1 | 5.3 | 26.3 | <2.0 |
| 09/04 | 28.4 | 7.1 | 5.9 | 22.3 | <2.0 |
| 09/05 | 29.0 | 7.3 | 10.7 | 32.4 | |
| 09/06 | 28.6 | 7.1 | 6.7 | 20.4 | |
| 09/07 | 28.7 | 7.1 | 9.9 | 22.4 | |
| 09/08 | 28.2 | 7.1 | 9.9 | 34.8 | <2.0 |
| 09/09 | 28.4 | 7.1 | 6.5 | 29.9 | <2.0 |
| 09/10 | 28.5 | 7.1 | 8.4 | 24.4 | 2.6 |
| 09/11 | 28.1 | 7.2 | 4.7 | 36.4 | <2.0 |
| 09/12 | 28.2 | 6.9 | 10.6 | 37.6 | |
| 09/13 | 28.3 | 7.0 | 8.4 | 30.8 | |
| 09/14 | 28.3 | 7.1 | 5.5 | 25.2 | |
| 09/15 | 29.1 | 6.9 | 8.4 | 28.0 | <2.0 |
| 09/16 | 29.0 | 6.9 | 8.6 | 34.0 | <2.0 |
| 09/17 | 29.0 | 6.9 | 8.1 | 30.8 | <2.0 |
| 09/18 | 28.6 | 7.0 | 8.3 | 24.8 | <2.0 |
| 09/19 | 29.7 | 7.0 | 6.6 | 21.7 | |
| 09/20 | 28.9 | 7.3 | 6.3 | 20.9 | |
| 09/21 | 28.8 | 7.0 | 5.9 | 23.3 | |
| 09/22 | 28.5 | 7.1 | 5.1 | 27.7 | <2.0 |
| 09/23 | 28.6 | 7.0 | 5.0 | 30.8 | <2.0 |
| 09/24 | 28.5 | 7.1 | 8.6 | 37.6 | 7.9 |
| 09/25 | 28.4 | 7.1 | 8.5 | 31.2 | 8.7 |
| 09/26 | 28.2 | 7.3 | 9.5 | 29.2 | |
| 09/27 | 28.1 | 7.2 | 8.9 | 30.0 | |
| 09/28 | 28.0 | 7.3 | 11.3 | 36.0 | |
| 09/29 | 27.6 | 7.2 | 10.1 | 32.0 | 4.5 |
| 09/30 | 27.8 | 7.1 | 10.8 | 36.3 | 2.3 |
| 平均值 | 28.5 | 7.1 | 8.0 | 28.9 | 3.1 |