

104 年 12 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
12/01	26.8	6.9	9.4	23.8	5.1
12/02	27.4	6.9	15.0	32.5	8.4
12/03	26.4	6.9	5.5	27.8	2.1
12/04	26.8	6.8	9.2	28.1	<2.0
12/05	26.5	6.8	17.4	40.6	
12/06	25.0	6.8	9.9	30.9	
12/07	26.7	6.8	10.9	31.7	
12/08	26.2	6.9	7.0	27.8	<2.0
12/09	26.8	6.9	12.0	29.4	<2.0
12/10	26.0	6.8	9.4	29.0	<2.0
12/11	26.5	6.9	10.0	25.4	3.5
12/12	26.3	6.9	11.4	26.6	
12/13	26.9	7.0	8.2	25.8	
12/14	26.7	7.0	8.4	25.8	
12/15	26.8	7.0	13.9	33.9	<2.0
12/16	26.4	7.0	10.8	33.5	<2.0
12/17	25.1	7.1	12.8	35.1	<2.0
12/18	25.2	6.9	9.9	35.5	<2.0
12/19	24.9	7.0	11.3	33.5	
12/20	25.2	7.0	9.3	30.3	
12/21	26.4	7.0	8.4	33.5	
12/22	26.6	7.0	10.2	32.4	<2.0
12/23	27.0	6.9	11.3	35.6	<2.0
12/24	27.2	6.9	13.6	34.5	<2.0
12/25	27.0	6.9	11.7	34.1	<2.0
12/26	25.8	6.9	15.5	40.2	3.1
12/27	26.6	7.0	13.8	38.6	
12/28	26.0	6.9	13.8	35.3	
12/29	25.5	6.8	14.5	31.2	<2.0
12/30	26.4	6.7	11.0	34.1	2.3
12/31	26.0	6.9	11.4	30.4	3.9
平均值	26.3	6.9	11.2	31.8	2.7