

## 105 年 4 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
04/01	26.2	7.1	7.0	30.8	<2.0
04/02	27.0	7.1	15.1	33.9	
04/03	27.4	7.1	14.9	26.7	
04/04	27.0	7.0	7.5	25.1	
04/05	27.0	7.0	10.6	33.9	
04/06	27.7	6.9	6.5	23.1	<2.0
04/07	27.5	7.0	6.9	30.8	2.2
04/08	27.7	7.0	5.2	30.9	2.2
04/09	26.1	7.0	4.8	23.9	
04/10	24.9	6.9	8.2	27.9	
04/11	27.1	6.9	5.1	33.9	
04/12	27.1	7.0	4.8	29.5	<2.0
04/13	27.4	7.1	13.4	29.8	4.1
04/14	27.1	7.0	7.5	26.1	4.4
04/15	26.9	6.9	5.4	22.5	<2.0
04/16	27.3	6.9	9.7	31.2	
04/17	28.5	6.9	9.1	28.0	
04/18	27.4	7.0	4.7	28.4	
04/19	27.1	7.0	6.8	30.8	<2.0
04/20	27.2	7.0	6.4	27.0	<2.0
04/21	27.8	6.9	5.7	32.1	2.4
04/22	27.9	6.9	7.5	29.3	<2.0
04/23	29.1	7.0	5.6	30.0	
04/24	28.7	6.9	8.4	30.0	
04/25	28.2	7.0	5.8	28.8	
04/26	27.8	7.1	5.5	31.5	2.4
04/27	28.4	7.0	6.2	30.4	3.8
04/28	28.3	7.0	5.8	30.6	5.0
04/29	27.8	7.1	3.8	31.4	<2.0
04/30	28.5	6.7	6.4	30.5	
平均值	27.5	7.0	7.3	29.3	2.7