

105 年 7 月科技部南部科學工業園區台南園區污水處理廠放流水質

| 日期 | Temp (°C) | pH | SS (mg/L) | COD (mg/L) | BOD ₅ (mg/L) |
|-------|-----------|-----|-----------|------------|-------------------------|
| 07/01 | 29.2 | 6.9 | 5.2 | 30.1 | <2.0 |
| 07/02 | 30.4 | 7.0 | 3.5 | 30.8 | |
| 07/03 | 30.6 | 7.0 | 10.2 | 28.4 | |
| 07/04 | 27.6 | 6.9 | 4.6 | 28.8 | |
| 07/05 | 29.3 | 7.0 | 4.6 | 32.0 | 2.2 |
| 07/06 | 29.5 | 6.9 | 3.6 | 25.5 | <2.0 |
| 07/07 | 29.1 | 7.0 | 5.3 | 32.0 | <2.0 |
| 07/08 | 28.5 | 7.0 | 7.9 | 31.7 | |
| 07/09 | 28.6 | 6.9 | 10.0 | 30.9 | |
| 07/10 | 28.9 | 6.9 | 9.1 | 27.7 | |
| 07/11 | 28.3 | 6.8 | 5.8 | 33.3 | |
| 07/12 | 28.8 | 6.8 | 10.0 | 27.8 | <2.0 |
| 07/13 | 28.7 | 6.8 | 4.5 | 26.4 | <2.0 |
| 07/14 | 29.0 | 6.8 | 4.2 | 27.5 | <2.0 |
| 07/15 | 29.2 | 6.9 | 6.2 | 29.8 | <2.0 |
| 07/16 | 29.3 | 6.9 | 3.8 | 27.3 | |
| 07/17 | 30.1 | 6.9 | 4.2 | 27.3 | |
| 07/18 | 29.2 | 6.7 | 3.2 | 29.7 | |
| 07/19 | 29.4 | 6.9 | 5.4 | 25.3 | <2.0 |
| 07/20 | 29.0 | 6.9 | <2.5 | 25.6 | <2.0 |
| 07/21 | 29.1 | 7.0 | 4.1 | 28.8 | <2.0 |
| 07/22 | 29.1 | 7.0 | 2.8 | 32.4 | 2.3 |
| 07/23 | 30.7 | 6.9 | 6.1 | 24.1 | |
| 07/24 | 30.7 | 6.9 | 5.8 | 22.5 | |
| 07/25 | 29.6 | 6.9 | 6.0 | 32.9 | |
| 07/26 | 29.4 | 7.0 | 6.0 | 33.9 | 8.4 |
| 07/27 | 29.5 | 6.9 | 6.8 | 28.5 | <2.0 |
| 07/28 | 29.3 | 6.9 | 8.4 | 32.0 | <2.0 |
| 07/29 | 29.5 | 6.9 | 9.5 | 31.2 | <2.0 |
| 07/30 | 30.2 | 6.9 | 15.0 | 33.1 | |
| 07/31 | 30.3 | 6.9 | 6.6 | 31.4 | |
| 平均值 | 29.4 | 6.9 | 6.2 | 29.3 | 2.4 |