

105 年 8 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/01	29.2	7.0	5.3	33.1	
08/02	28.9	7.1	9.0	33.5	8.2
08/03	29.3	7.0	4.1	31.4	6.7
08/04	29.2	7.0	9.0	27.3	<2.0
08/05	29.4	7.0	5.9	30.5	<2.0
08/06	29.5	6.9	8.7	34.4	
08/07	29.8	6.9	9.2	33.2	
08/08	29.0	6.9	11.8	31.6	
08/09	29.4	6.8	6.8	32.4	2.5
08/10	29.4	7.0	5.9	30.6	<2.0
08/11	29.0	6.9	14.9	31.4	<2.0
08/12	28.9	7.0	4.5	28.2	<2.0
08/13	30.0	6.8	13.3	27.7	
08/14	29.0	6.8	12.7	30.9	
08/15	29.2	6.9	9.5	34.1	
08/16	28.9	7.5	6.1	34.1	6.0
08/17	29.0	7.0	16.6	32.1	7.0
08/18	29.1	7.1	12.1	25.6	<2.0
08/19	29.0	7.0	7.3	30.4	<2.0
08/20	30.0	7.0	4.8	29.0	
08/21	29.9	7.0	6.4	26.6	
08/22	29.3	7.0	4.0	28.2	
08/23	29.3	7.0	4.4	34.1	<2.0
08/24	29.5	7.1	2.9	28.9	<2.0
08/25	29.4	7.0	8.1	30.1	<2.0
08/26	29.5	7.0	5.4	25.6	<2.0
08/27	30.9	7.1	8.0	27.4	
08/28	30.5	7.0	5.6	29.0	
08/29	29.3	7.1	4.7	32.7	
08/30	29.0	7.1	6.4	27.3	<2.0
08/31	28.8	7.2	4.6	27.3	<2.0
平均值	29.4	7.0	7.7	30.3	3.1