

105 年 11 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	27.8	7.0	6.2	25.2	3.2
11/02	28.1	7.0	13.4	27.5	2.8
11/03	27.4	7.1	9.1	25.5	<2.0
11/04	27.8	7.1	8.7	27.5	<2.0
11/05	28.2	7.0	9.1	23.4	
11/06	27.9	7.1	7.0	26.6	
11/07	28.1	6.9	12.7	28.2	
11/08	28.1	6.9	7.3	24.8	<2.0
11/09	27.9	7.0	5.2	26.4	<2.0
11/10	27.1	6.9	13.4	26.4	<2.0
11/11	27.5	6.9	17.3	25.6	<2.0
11/12	29.8	6.9	4.4	23.8	
11/13	29.0	6.8	5.7	23.8	
11/14	28.2	6.6	8.5	23.8	
11/15	27.8	7.0	8.8	24.4	<2.0
11/16	28.0	7.0	8.2	22.4	2.1
11/17	27.8	7.1	14.4	28.7	<2.0
11/18	27.9	6.7	17.8	27.9	<2.0
11/19	28.7	7.0	5.0	27.0	
11/20	28.6	7.0	7.0	26.2	
11/21	28.0	6.8	5.8	25.8	
11/22	28.0	7.0	9.9	24.0	<2.0
11/23	27.8	6.9	10.6	26.7	<2.0
11/24	26.8	6.9	12.6	27.9	3.0
11/25	26.8	6.9	12.2	27.8	<2.0
11/26	28.0	7.0	6.3	23.4	
11/27	24.2	7.1	4.8	25.4	
11/28	26.3	7.1	6.3	25.4	
11/29	26.2	6.9	6.8	24.0	<2.0
11/30	26.5	7.0	3.2	25.1	2.1
平均值	27.7	7.0	8.9	25.7	2.2