

106 年 2 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
02/01	25.3	7.0	6.3	24.3	
02/02	25.9	7.0	5.4	25.3	<2.0
02/03	25.6	7.1	12.8	27.5	2.6
02/04	20.4	7.0	11.1	24.6	
02/05	25.6	7.2	<2.5	23.8	
02/06	25.6	7.0	10.3	25.4	
02/07	25.7	7.3	3.7	24.2	<2.0
02/08	25.8	7.1	5.7	20.8	<2.0
02/09	25.4	7.1	<2.5	21.6	<2.0
02/10	23.8	7.0	3.8	23.2	<2.0
02/11	23.1	7.2	5.5	22.7	
02/12	24.7	7.1	4.6	22.7	
02/13	24.8	7.1	7.4	22.3	
02/14	23.6	7.2	3.1	21.0	<2.0
02/15	25.1	7.3	4.6	21.8	<2.0
02/16	25.5	7.1	4.5	22.8	<2.0
02/17	25.2	7.2	8.6	24.4	<2.0
02/18	25.5	7.1	5.1	27.9	
02/19	25.6	7.2	3.8	25.5	
02/20	26.5	7.0	4.1	25.5	
02/21	26.4	7.5	3.6	28.0	<2.0
02/22	26.4	7.0	10.4	29.6	<2.0
02/23	27.2	7.1	3.6	24.3	<2.0
02/24	25.8	7.2	4.1	27.5	2.5
02/25	25.5	7.0	4.5	25.8	
02/26	25.2	7.1	5.9	27.0	
02/27	25.7	7.1	5.4	24.6	
02/28	26.4	7.2	5.5	27.8	
平均值	25.3	7.1	5.7	24.7	2.1