

106 年 5 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
05/01	27.6	6.9	3.6	31.0	
05/02	27.9	7.0	3.0	28.0	<2.0
05/03	28.4	6.9	4.4	30.8	<2.0
05/04	28.6	7.0	2.9	32.8	4.3
05/05	28.6	7.0	6.1	33.9	4.9
05/06	28.8	6.9	7.4	26.2	
05/07	28.5	6.9	9.9	25.4	
05/08	28.6	6.9	3.4	25.4	
05/09	28.8	6.8	2.8	31.0	<2.0
05/10	29.1	6.8	3.5	28.8	2.0
05/11	28.9	6.8	3.4	27.0	<2.0
05/12	29.0	6.8	4.2	29.6	<2.0
05/13	29.2	7.0	4.5	29.1	
05/14	29.9	6.9	<2.5	27.5	
05/15	29.2	6.8	3.6	25.5	
05/16	28.7	6.8	3.2	26.3	<2.0
05/17	28.3	6.8	5.1	24.8	<2.0
05/18	28.5	7.0	5.9	26.4	<2.0
05/19	28.3	7.1	5.1	25.5	<2.0
05/20	27.9	7.0	6.6	25.9	
05/21	28.4	7.0	4.6	25.1	
05/22	28.8	6.9	3.5	29.1	
05/23	28.9	6.8	4.2	27.0	<2.0
05/24	29.0	6.9	9.0	34.7	<2.0
05/25	28.8	6.9	4.5	30.0	<2.0
05/26	28.5	7.0	3.7	29.2	<2.0
05/27	28.9	7.0	6.9	27.9	
05/28	29.0	6.9	3.8	27.1	
05/29	29.2	6.9	3.4	26.3	
05/30	29.1	6.9	2.6	27.1	
05/31	28.2	6.9	4.5	26.3	3.3
平均值	28.7	6.9	4.6	28.1	2.4