

106年9月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
09/01	29.2	6.8	<2.5	27.3	<2.0
09/02	29.5	6.6	4.4	24.9	
09/03	29.6	6.2	4.2	27.3	
09/04	29.4	6.7	3.4	24.1	
09/05	29.4	6.8	3.2	25.3	2.3
09/06	29.5	7.1	4.2	25.5	<2.0
09/07	29.8	7.4	3.4	24.7	<2.0
09/08	27.4	7.0	9.4	30.0	6.7
09/09	29.9	6.7	5.6	26.2	
09/10	29.4	6.8	3.9	27.9	
09/11	29.3	7.2	3.5	25.8	
09/12	29.3	7.0	7.1	25.0	<2.0
09/13	29.4	7.1	3.2	26.6	<2.0
09/14	29.2	7.0	3.5	28.6	<2.0
09/15	29.0	7.0	4.5	27.9	<2.0
09/16	29.0	7.0	4.4	25.5	
09/17	29.0	7.0	2.9	27.1	
09/18	29.1	7.1	<2.5	27.9	
09/19	29.2	7.0	2.5	26.2	<2.0
09/20	29.0	7.0	6.3	26.1	<2.0
09/21	29.1	7.0	2.8	27.7	<2.0
09/22	29.4	6.8	6.2	26.5	<2.0
09/23	27.5	6.8	4.0	29.1	
09/24	29.2	6.8	4.8	29.1	
09/25	29.4	6.7	6.2	29.9	
09/26	29.7	6.7	4.5	28.7	<2.0
09/27	29.7	7.0	8.0	32.4	<2.0
09/28	29.6	7.2	5.2	29.9	
09/29	29.5	7.0	4.8	27.4	<2.0
09/30	29.4	7.1	4.8	27.7	<2.0
平均值	29.2	6.9	4.5	27.3	2.3