

107 年 05 月南部科學園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
05/01	28.6	6.8	5.8	30.0	<2.0
05/02	28.7	6.5	7.1	23.8	<2.0
05/03	28.9	6.8	4.4	31.2	<2.0
05/04	28.6	6.7	4.4	24.2	<2.0
05/05	29.1	6.9	4.3	28.9	
05/06	29.3	6.8	4.0	28.5	
05/07	28.8	7.0	4.6	29.7	
05/08	28.8	7.0	4.4	28.5	6.3
05/09	28.3	6.9	4.3	24.1	2.3
05/10	28.4	6.9	3.9	24.9	<2.0
05/11	28.6	7.1	3.0	25.5	<2.0
05/12	28.6	6.6	4.9	23.5	
05/13	28.5	7.3	4.6	25.5	
05/14	28.8	7.0	3.9	24.7	
05/15	29.2	7.0	3.1	26.5	<2.0
05/16	29.2	6.9	2.9	26.3	<2.0
05/17	29.4	7.1	2.9	26.2	2.4
05/18	29.2	6.9	<2.5	32.1	<2.0
05/19	29.3	6.8	3.4	24.8	
05/20	28.6	7.0	<2.5	26.4	
05/21	29.6	6.9	2.6	24.4	
05/22	29.4	7.0	<2.5	33.5	<2.0
05/23	29.6	6.9	2.9	27.2	<2.0
05/24	29.6	7.0	<2.5	34.1	<2.0
05/25	29.6	7.0	<2.5	29.8	<2.0
05/26	22.8	7.0	5.8	27.2	
05/27	30.3	6.9	<2.5	28.4	
05/28	30.0	7.0	2.7	30.0	
05/29	30.0	6.9	<2.5	25.8	<2.0
05/30	30.0	6.9	<2.5	30.5	<2.0
05/31	30.0	6.9	2.8	23.3	<2.0
平均值	29.0	6.9	3.6	27.4	2.3