

## 107 年 07 月南部科學園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
07/01	26.0	6.9	4.5	29.8	
07/02	28.4	7.0	3.7	28.1	
07/03	28.4	7.0	3.2	23.3	<2.0
07/04	28.5	7.0	<2.5	26.9	<2.0
07/05	28.6	6.7	4.2	22.9	<2.0
07/06	28.6	6.9	4.4	28.8	<2.0
07/07	29.1	7.1	2.8	21.2	
07/08	29.8	6.9	2.8	21.2	
07/09	29.2	6.9	3.5	23.3	
07/10	29.0	6.9	3.4	26.5	<2.0
07/11	29.0	6.9	3.4	25.1	5.9
07/12	29.0	6.9	3.4	24.6	3.5
07/13	29.0	7.0	3.0	23.6	<2.0
07/14	29.8	7.0	9.6	21.3	
07/15	30.0	7.0	10.0	29.7	
07/16	29.6	6.6	13.0	24.5	
07/17	29.4	6.8	5.3	26.1	3.0
07/18	29.6	6.9	5.8	22.3	<2.0
07/19	29.4	6.9	5.1	24.7	<2.0
07/20	29.4	6.9	4.3	24.9	<2.0
07/21	29.7	7.0	6.1	27.9	
07/22	29.3	6.9	3.2	25.1	
07/23	29.2	7.0	2.8	26.7	
07/24	29.2	6.9	3.1	22.9	<2.0
07/25	29.4	7.0	3.2	29.0	<2.0
07/26	29.4	7.1	4.6	20.9	<2.0
07/27	29.4	7.0	3.1	24.6	<2.0
07/28	29.2	7.0	3.8	28.6	
07/29	29.3	7.0	3.8	25.0	
07/30	29.5	7.0	3.3	23.8	<2.0
07/31	30.2	6.9	4.5	24.2	
平均值	29.1	6.9	4.5	25.1	2.4