

107 年 10 月南部科學園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
10/01	28.6	6.7	4.1	20.0	
10/02	28.6	6.8	4.8	22.0	<2.0
10/03	28.4	6.7	4.6	27.0	<2.0
10/04	27.8	6.7	5.6	25.7	<2.0
10/05	27.6	6.6	5.6	32.0	<2.0
10/06	29.0	6.8	4.9	25.7	
10/07	29.2	6.5	5.7	20.6	
10/08	28.6	6.5	6.2	20.9	
10/09	28.6	6.8	2.8	28.3	<2.0
10/10	29.5	6.7	3.0	25.3	
10/11	28.4	6.7	3.6	27.6	<2.0
10/12	27.2	6.7	<2.5	27.3	<2.0
10/13	29.0	6.8	3.4	27.3	
10/14	28.0	6.6	5.8	25.3	
10/15	28.2	6.9	3.4	25.3	
10/16	28.4	6.8	3.0	23.0	<2.0
10/17	28.2	6.8	4.4	26.9	<2.0
10/18	28.0	6.7	4.6	25.1	<2.0
10/19	27.6	6.9	3.0	23.5	<2.0
10/20	27.8	6.8	4.2	25.9	
10/21	27.5	6.7	2.8	26.3	
10/22	28.2	6.7	3.8	24.3	
10/23	28.0	6.8	4.3	20.4	<2.0
10/24	28.0	6.8	4.7	28.7	<2.0
10/25	28.2	6.8	4.6	26.3	<2.0
10/26	28.0	6.9	4.4	23.8	<2.0
10/27	27.9	6.9	4.3	26.6	
10/28	26.9	6.9	4.4	27.4	
10/29	27.0	6.8	7.4	24.6	
10/30	27.0	6.8	3.4	21.6	<2.0
10/31	27.2	6.8	3.1	23.2	<2.0
平均值	28.1	6.8	4.3	25.1	<2.0