

108 年 04 月南部科學園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
04/01	26.5	6.6	4.3	23.6	<2.0
04/02	26.6	6.5	4.1	21.9	<2.0
04/03	26.8	7.0	6.7	24.0	<2.0
04/04	28.5	6.4	8.3	23.6	
04/05	28.0	6.5	6.4	28.8	
04/06	28.6	6.5	8.0	29.6	
04/07	28.2	6.4	8.6	27.2	
04/08	27.4	6.7	6.1	28.0	
04/09	27.6	6.7	9.4	28.0	<2.0
04/10	27.6	6.7	4.8	22.6	<2.0
04/11	28.0	6.7	5.4	34.6	<2.0
04/12	27.2	6.8	5.1	21.4	<2.0
04/13	27.3	6.6	4.9	23.7	
04/14	27.8	6.6	7.5	22.1	
04/15	26.8	6.6	6.8	24.9	
04/16	27.1	6.8	5.5	23.7	2.1
04/17	27.0	6.7	3.9	25.7	<2.0
04/18	27.4	6.7	4.0	20.7	<2.0
04/19	27.5	6.7	5.3	26.8	2.4
04/20	28.3	6.6	4.9	22.2	
04/21	27.3	6.3	5.5	20.6	
04/22	27.7	6.6	5.2	20.6	
04/23	28.0	6.6	4.8	20.5	<2.0
04/24	28.0	6.7	3.5	21.0	<2.0
04/25	27.8	6.6	4.3	20.9	2.8
04/26	28.0	6.5	8.0	23.3	2.8
04/27	29.2	6.4	5.6	18.1	
04/28	29.4	6.4	7.1	26.9	
04/29	28.0	6.5	8.6	26.5	
04/30	28.5	6.5	4.4	21.5	<2.0
平均值	27.7	6.6	5.9	24.1	2.1