

108 年 06 月南部科學園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	28.8	6.6	4.3	22.8	
06/02	29.3	6.5	6.0	21.2	
06/03	29.0	6.6	4.5	21.6	<2.0
06/04	28.8	6.5	6.5	31.2	<2.0
06/05	28.9	6.5	3.2	26.0	<2.0
06/06	29.0	6.8	4.4	29.3	<2.0
06/07	29.9	6.7	4.5	24.2	
06/08	30.2	6.6	4.3	26.2	
06/09	29.9	6.6	4.7	24.6	
06/10	29.3	6.7	4.0	23.0	
06/11	28.3	6.8	7.1	23.6	<2.0
06/12	28.4	6.7	6.2	28.8	<2.0
06/13	28.8	6.7	3.9	31.8	<2.0
06/14	28.6	6.7	5.2	25.4	<2.0
06/15	29.2	6.5	3.7	30.6	
06/16	29.3	6.5	5.3	27.4	
06/17	28.9	6.6	4.9	32.6	
06/18	28.8	6.6	5.0	31.8	<2.0
06/19	29.4	6.5	6.0	24.8	<2.0
06/20	29.4	6.5	6.9	27.4	<2.0
06/21	29.2	6.6	8.8	30.2	<2.0
06/22	30.3	6.5	9.1	27.0	
06/23	30.1	6.5	8.1	28.6	
06/24	28.8	6.7	7.3	29.0	
06/25	28.8	6.7	5.9	28.4	<2.0
06/26	28.5	6.7	2.8	27.6	<2.0
06/27	28.9	6.6	5.9	30.4	<2.0
06/28	29.2	6.8	2.8	31.8	<2.0
06/29	30.2	6.5	8.9	33.8	
06/30	31.2	6.5	7.6	29.8	
平均值	29.2	6.6	5.6	27.7	<2.0