

2019 年 12 月南部科學園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
12/01	28.7	6.5	2.7	22.7	—
12/02	26.0	6.7	3.4	22.3	—
12/03	25.8	6.8	2.7	28.8	<2.0
12/04	25.8	6.8	3.8	23.3	<2.0
12/05	25.4	6.6	2.8	27.5	<2.0
12/06	24.9	6.8	5.5	23.5	<2.0
12/07	26.7	6.5	4.0	20.2	—
12/08	24.6	6.7	3.2	22.6	—
12/09	25.3	6.7	4.6	23.8	—
12/10	25.5	6.7	3.8	25.7	<2.0
12/11	25.6	6.8	5.5	22.5	<2.0
12/12	25.7	6.8	3.8	25.1	<2.0
12/13	25.5	6.8	3.8	20.9	<2.0
12/14	25.0	6.8	3.3	19.8	—
12/15	25.6	6.8	3.4	19.8	—
12/16	26.1	6.7	4.0	27.0	—
12/17	26.2	6.7	3.5	26.9	<2.0
12/18	26.4	6.7	5.7	25.9	<2.0
12/19	26.6	6.8	5.0	23.5	<2.0
12/20	25.6	6.7	4.4	22.0	<2.0
12/21	25.8	6.8	5.1	20.6	—
12/22	25.8	6.8	3.7	24.2	—
12/23	26.5	6.8	4.5	26.2	—
12/24	26.2	6.9	5.3	24.1	<2.0
12/25	26.1	6.6	3.2	23.7	<2.0
12/26	26.3	6.8	5.3	27.1	<2.0
12/27	24.4	6.6	3.9	25.5	<2.0
12/28	25.4	6.7	4.2	22.2	—
12/29	27.9	6.4	8.1	21.0	—
12/30	26.1	6.6	5.2	24.6	<2.0
12/31	25.8	6.6	3.8	24.9	<2.0
平均值	25.9	6.7	4.2	23.8	<2.0